

# NRTL\* Approvals



## M1 Gas Monitor

CSA Approved C22.2 No 1010.1 & 152 for combustibles & ISA S82.02 Instrument enclosure suitable for Class 1, Div 1 & 2 (Groups B, C, D) and Class 2, Div 1 & 2 (Groups E, F, G). NEMA 3, 4, 7, BCD, 9 EFG, CENELEC - EEx d II B IP66.



## GASMAX / EC Gas Monitor

CSA Approved GASMAX for Class 1, Div 1 & 2 (Groups B, C, D) Exia. Suitable for Explosion Proof installations.  
CSA Approved GASMAX for Class 1, Div 1 & 2 (Groups A, B, C, D). Suitable for Intrinsically Safe installations only\*

\* **Important**—Intrinsically Safe installations require IS barrier #10-0263 (MTL 7787) or equivalent



## GASMAX II Gas Monitor

CSA Approved GASMAX for Class 1, Div 1 & 2 (Groups B, C, D) Suitable for Explosion Proof installations.  
ATEX Certified for use in hazardous areas as follows:  
II 2 G EEx d IIB + H<sub>2</sub> T5




## GDS-49 Sensor Transmitter

CSA Approved 10-0248 (GDS-49) for Class 1, Div 1 & 2 (Groups B, C, D) Exia. Suitable for Explosion Proof and Intrinsically Safe installations\*  
CSA Approved for Class 1, Div 1 & 2 (Groups A, B, C, D). Suitable for Intrinsically Safe installations\*.



## GDS-IR Infrared Combustible Gas Detector

CSA Approved C22.2 No 152; approved for Class 1, Div 1 (Groups B, C, D).



## C1 Protector Sixteen Channel Controller

CSA Approved C22.2 No 1010.1 & 152 for combustibles & ISA S82.02; UL 1604 / C22.2 No 213 (Div 2 Grp A, B, C, D); EN55011 & EN61000 (CE Mark)

Available in standard panel mount, NEMA 4X enclosure for Class 1, Div 2 (Groups A, B, C, D) and NEMA 7 explosion proof enclosure for Class 1, Div 1 (Groups B, C, D)



## C2 Protector Two Channel Controller

CSA Approved C22.2 No 1010.1 & 152 for combustibles & ISA S82.02; UL 1604 / C22.2 No 213; EN55011 & EN61000 (CE Mark)  
Available in NEMA 4X enclosure for Class 1, Div 2 (Groups A, B, C, D) or NEMA 7 explosion proof enclosure for Class 1, Div 1 (Groups B, C, D)

### Important:

The final selection and placement of monitors, detectors, alarms and readouts in any gas detection system is extremely critical to safety. Only experienced and qualified personnel who are familiar with the application and all applicable regulations and best engineering practices

\* Nationally Recognized Testing Laboratory

All specifications subject to change without notice.  
© 2006 Global Detection Systems Corp. All Rights Reserved